



**HAL**  
open science

# A Novel Control Technique for Voltage Balancing in Bipolar DC Microgrids

Hajar Doubabi, Issam Salhi, Najib Essounbouli

► **To cite this version:**

Hajar Doubabi, Issam Salhi, Najib Essounbouli. A Novel Control Technique for Voltage Balancing in Bipolar DC Microgrids. *Energies*, MDPI, 2022, 15 (9), pp.3368. 10.3390/en15093368 . hal-03660522

**HAL Id: hal-03660522**

**<https://hal.univ-reims.fr/hal-03660522>**

Submitted on 6 May 2022

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Distributed under a Creative Commons Attribution| 4.0 International License

Article

# A Novel Control Technique for Voltage Balancing in Bipolar DC Microgrids

Hajar Doubabi <sup>1,2,\*</sup>, Issam Salhi <sup>3</sup> and Najib Essounbouli <sup>1</sup>

<sup>1</sup> CReSTIC, Reims University, 9 rue de Québec B.P 396, 10026 Troyes, France; najib.essounbouli@univ-reims.fr

<sup>2</sup> CISIEV, Faculty of Sciences and Technology, Cadi Ayyad University, Marrakesh 40000, Morocco

<sup>3</sup> FEMTO-ST Institute, University Bourgogne Franche-Comté, UTBM, CNRS, Rue Thierry Mieg, 90000 Belfort, France; issam.salhi@utbm.fr#

\* Correspondence: hajardoubabi@gmail.com

**Abstract:** The bipolar DC microgrid topology is characterized by three voltage levels and is able to transfer power more efficiently than a conventional DC microgrid. This paper proposes an advanced control strategy aiming to ensure the voltage balancing between the upper and lower terminals of a bipolar DC microgrid regardless of the distribution of loads. The proposed controller is based on the backstepping method, which is well known for its the robustness and the global asymptotic stability that can be guaranteed for the system. A particle swarm optimization algorithm has also been adopted for an optimal design of the proposed controller parameters. Simulation results in a Matlab/Simulink environment has been presented to verify the effectiveness and reliability of the proposed voltage-balancing controller.

**Keywords:** voltage balancing control; bipolar DC microgrid; three-level DC–DC step-up converter

**Citation:** Doubabi, H.; Salhi, I.; Essounbouli, N. A Novel Control Technique for Voltage Balancing in Bipolar DC Microgrids. *Energies* **2022**, *15*, 3368. <https://doi.org/10.3390/en15093368>

Academic Editor: Luis Hernández-Callejo

Received: 21 March 2022

Accepted: 28 April 2022

Published: 5 May 2022

**Publisher's Note:** MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



**Copyright:** © 2022 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).


## 1. Introduction

A microgrid has been defined according to CORDIS Europe as an advanced electric system formed of a series of electrical loads, power source elements (photovoltaic (PV) systems, fuel cells, wind turbines, etc.) and storage (batteries, flywheel, compressed air, etc.) connected to the local grid through a single point of connection. The microgrid integrates management strategies controlling both the energy flow within the microgrid itself and the interchange of power with the supply grid [1]. One of the most important features of microgrids is that they are able to operate in two modes: the grid-connected mode and the islanded (off-grid) mode [2]. Microgrids can be built in rural and urban areas at multiple scales: low (such as a house/building with PV panels), medium (such as a factory) and large (such as a big university campus [3]).

Over the last two decades, significant progress has been made in DC/DC power converters, energy storage technologies (batteries, supercapacitor, etc.) and DC-based distributed energy resources (solar photovoltaics, fuel cell, etc.) [4]. In addition, an increasing number of DC-consuming devices such as LEDs, televisions, monitors and computers have been integrated into buildings. In addition, and new emerging technologies such as electric vehicles are DC [4]. Therefore, DC microgrids have become an attractive option and present a promising alternative to the AC counterpart. Various research studies have been focused on comparing the DC and AC microgrids [5–7]. It has been revealed that DC microgrids can transmit significantly more energy through distribution lines and require fewer power conversion stages, which decrease not only losses but also costs. DC microgrids present higher levels of power quality that are strongly intertwined with voltage stability. Moreover, DC microgrid control is simpler as there is no need for frequency

synchronization and reactive power management. Despite the multiple merits of DC microgrids [8], appropriate control and safe design is always needed to avoid potential issues and maximize their benefits [4].

There are two wiring configurations of DC microgrids [9]: the unipolar (two-wire) and the bipolar (three-wire) configurations. This paper particularly addresses the bipolar configuration that generally offers two voltage levels: a positive to neutral or negative to neutral voltage ( $\pm 350$  V) and a positive to negative voltage (700 V), as shown in Figure 1. A voltage level of  $\pm 350$  V has been considered in this paper since it is the most widely adopted level at the low- to medium-voltage bipolar DC power distribution network [10]. Among the key features of the bipolar configuration is that the loads can be connected at the appropriate voltage level due to the availability of two levels. Furthermore, the bipolar system may potentially continue supplying the loads under fault occurrence or loss of one pole. To summarize, the bipolar configuration has been proven to provide additional merits compared to conventional unipolar DC microgrids, including a high level of power transmission capability, reliability and efficiency [11]. Nevertheless, the bipolar DC microgrids still encounter some challenges that are not yet fully investigated [12].




**Figure 1.** The bipolar DC microgrid architecture.

First, the unequal load distribution across the positive and negative poles leads to voltage unbalance in the bipolar DC microgrid, which is undesirable owing to its impact on efficiency, power quality and stability [4]. To solve this problem, available literature has proposed the so-called voltage balancer that is a power electronic block commonly integrated with the grid-connected inverter, and it is able to equalize both poles' voltages. In [10], the authors provide a comprehensive analysis of voltage balancers and introduce their different topologies. However, most studies have examined the voltage unbalance issue in a bipolar DC microgrid operating in grid-connected mode. Very little research has considered the islanded mode as well.

Otherwise, power electronic converters are fundamental elements in DC distribution. AC/DC and DC/DC converters are the two converter types commonly used in DC microgrids. To achieve a robust and efficient DC microgrid, an accurate design and control of the converters is required. Numerous studies have been conducted to improve the AC/DC converter's structure [13–15] and enhance the system stability by proposing different linear [16] and nonlinear [17] control strategies. However, few studies on bipolar DC microgrids have focused on proposing improved design and developing advanced control techniques for DC/DC converters; the latter plays an equally essential role in DC microgrids as the AC/DC converters.

Due to the large accessibility and abundance, the PV solar plant is one of the most installed renewable power sources in DC microgrids. The PV system is connected to the bipolar DC bus through a DC/DC converter as depicted in Figure 1. This converter is the main interface that adapts the voltage level between the PV system and the DC bus. The majority of studies [18] on bipolar DC microgrids are generally confined to classical DC/DC converter topologies such as the conventional boost converter. Nevertheless, when the PV system is the principal power supply during islanded mode, the PV converter becomes the key element that must maintain the stability and reliability of the microgrid. Hence, more attentive design and control of the PV-connected DC/DC converter is needed.

The three-level boost converter topology shown in Figure 2 can be considered as a good candidate for the PV-connected DC/DC converter on the bipolar DC microgrids. This topology with two conversion stages can improve the system reliability. If an operational failure occurs in one stage or one DC bus, the converter continues working as a conventional topology. Additional merits of this suggested converter topology are the low switching losses, low voltage stress for semiconductor devices and reduced inductor current ripples [19].



**Figure 2.** The PV-connected DC/DC three-level boost converter topology.

This paper proposes a new robust voltage balance control based on a backstepping approach for a PV-connected DC/DC three-level boost converter on bipolar DC microgrids. The backstepping control method was chosen for its three significant superiorities compared to other control methods, namely the global asymptotic stability, the robustness and guaranteed transient performance.

The particle swarm optimization (PSO) algorithm is widely adopted as an optimized tuner due to its easy execution, quick convergence and its computational efficiency [20]. Therefore, a PSO technique has been used in this study to optimally predict the design parameters of the synthesized backstepping control law.

According to the above discussion, the contributions of this paper can be summarized as follows:

1. A novel voltage-balancing control based on a backstepping approach was proposed for a bipolar DC microgrid supplying unbalanced loads through a PV-fed three-level boost DC/DC converter. The proposed control technique enables reliable and accurate voltage balancing.
2. The PSO algorithm was used for an optimal estimation of the parameter's values of the proposed backstepping-based controller.
3. The present work is supported by a theoretical study and validated through simulations under Matlab/Simulink.

The paper is structured as follows. The three-level DC/DC boost converter structure and operation are introduced in Section 2. The proposed voltage-balancing control is presented in detail in Section 3. In Section 4, simulation results verifying the working and performance of the developed controller are discussed. Finally, the conclusion is drawn in Section 5.

## 2. Three-Level DC/DC Boost Converter

### 2.1. Topology Description

The three-level DC/DC boost converter (TLBC) topology shown in Figure 2 has three connection points (labeled  $p$ ,  $o$  and  $n$ ) enabling a three-terminal connection to the bipolar DC microgrid presented in Figure 1 (positive, neutral and negative, respectively). It consists of two power switches (MOSFETs) M1 and M2, diodes D1 and D2, an inductor L and two capacitors C1 and C2. Compared to other converters with the same function in the literature, this converter is more economical as it uses only two switches and one inductor. Among the main features of this topology are the low switching losses as one switch needs to handle only half the DC output voltage when it conducts, and the low inductor current ripple as the voltage across the inductor has three levels. Moreover, it is well known that the PV system maximum voltage rating can easily exceed the range that a single switching device can withstand. Therefore, the use of such multistage topology can be considered as a suitable solution of this issue.

### 2.2. Topology Operation

#### 2.2.1. Symmetrical Operation


In the TLBC, the switches are driven by two PWMs with the same duty cycle ( $d_1 = d_2 = d \in \{0,1\}$ ) and a phase difference of  $180^\circ$ . During symmetrical operation, capacitor voltages are considered equal  $V_1 = V_2$ . As can be seen in Figure 3, the converter operates in four principal states as follow:


State1 (Figure 3a): Both switches (M1 and M2) are 'on'; the inductor is in charging mode. The capacitors C1 and C2 discharge their energy into the load.

State2 (Figure 3b): M1 is 'on' while M2 is 'off'; the inductor can be in charging or discharging mode depending on the operating region. C2 is in the charging mode and C1 is discharging.

State3 (Figure 3c): When M2 is 'on' and M1 is 'off', the inductor can be in charging or discharging mode depending on the operating region. C1 is in charging mode and C2 is discharging.

State4 (Figure 3d): Both switches (M1 and M2) are 'off'; the inductor is in discharging mode. The input source transmits energy to the output and satisfies the current demand via both capacitors.






**Figure 3.** Possible states of the three-level DC/DC boost converter in CCM: (a) State1; (b) State2; (c) State3; and (d) State4.

The TLBC operates in two regions depending on whether the input voltage ( $V_{pv}$ ) is higher or lower than half of the output voltage ( $V_o = V_1 + V_2$ ). Figure 4a shows the waveforms for the first region: " $V_{pv} \geq 1/2V_o$ "  $\Leftrightarrow$  " $d \leq 0.5$ " and Figure 4b for the second region: " $V_i < 1/2V_o$ "  $\Leftrightarrow$  " $d > 0.5$ ".


With symmetry,  $V_1$  and  $V_2$  are theoretically balanced as the inductor charges the capacitors alternatively.



**Figure 4.** Symmetrical operation of TLSC: (a)  $d > 0.5$ ; and (b)  $d \leq 0.5$  ( $i_L$  is the inductor current).

### 2.2.2. Asymmetrical Operation

When the TLBC is used in the bipolar DC microgrid as presented in Figure 1, the loads on the upper and lower terminals (positive to neutral and negative to neutral) are generally not the same; hence, the load currents  $I_1$  and  $I_2$  will be unequal. These result in asymmetrical operation as depicted in Figure 5. In this case, one of the capacitor voltages go beyond the switch breakdown voltage, which may lead to switch damage. Therefore, the converter must be controlled to keep the voltages across  $C_1$  and  $C_2$  balanced whatever the nominal values of the connected loads.



**Figure 5.** Asymmetrical operation of TLBC: (a)  $d > 0.5$ ; and (b)  $d \leq 0.5$  ( $i_L$  is the inductor current).

### 2.3. Mathematical Modeling

Operating in continuous conduction mode CCM, the corresponding model of each state  $i \in \{1, 2, 3, 4\}$  has the form

$$\dot{x}(t) = A_i x(t) + B_i \tag{1}$$

where  $x = [V_1 \ i_L \ V_2]^T$  is the state vector consists of voltages across capacitors and inductor current.

State1  $i = 1$

$$\dot{x}(t) = A_1 x(t) + B_1 = \begin{bmatrix} -\frac{I_1}{C_1} \\ \frac{V_{pv}}{L} \\ -\frac{I_2}{C_2} \end{bmatrix} \tag{2}$$

State2  $i = 2$

$$\dot{x}(t) = A_2 x(t) + B_2 = \begin{bmatrix} 0 & 0 & 0 \\ 0 & 0 & -\frac{1}{L} \\ 0 & \frac{1}{C_2} & 0 \end{bmatrix} x(t) + \begin{bmatrix} -\frac{I_1}{C_1} \\ \frac{V_{pv}}{L} \\ -\frac{I_2}{C_2} \end{bmatrix} \tag{3}$$

State3  $i = 3$

$$\dot{x}(t) = A_3 x(t) + B_3 = \begin{bmatrix} 0 & \frac{1}{C_1} & 0 \\ -\frac{1}{L} & 0 & 0 \\ 0 & 0 & 0 \end{bmatrix} x(t) + \begin{bmatrix} -\frac{I_1}{C_1} \\ \frac{V_{pv}}{L} \\ -\frac{I_2}{C_2} \end{bmatrix} \quad (4)$$

State4  $i = 4$

$$\dot{x}(t) = A_3 x(t) + B_3 = \begin{bmatrix} 0 & \frac{1}{C_1} & 0 \\ -\frac{1}{L} & 0 & -\frac{1}{L} \\ 0 & \frac{1}{C_2} & 0 \end{bmatrix} x(t) + \begin{bmatrix} -\frac{I_1}{C_1} \\ \frac{V_{pv}}{L} \\ -\frac{I_2}{C_2} \end{bmatrix} \quad (5)$$

The final model of the converter is obtained by multiplexing all its four states as follows:

$$\dot{x} = (A_1 \bar{d}_1 \bar{d}_2 + A_2 \bar{d}_1 d_2 + A_3 d_1 \bar{d}_2 + A_4 d_1 d_2) x + (B_1 \bar{d}_1 \bar{d}_2 + B_2 \bar{d}_1 d_2 + B_3 d_1 \bar{d}_2 + B_4 d_1 d_2) \quad (6)$$

$d_1$  and  $d_2$  are the duty cycles piloting M1 and M2, respectively; thus, they are control variables representing the two switches' states.

After substitution and simplification, we obtain:

$$\dot{x} = A(d)x + B = \begin{bmatrix} 0 & \frac{1-d}{C_1} & 0 \\ -\frac{1-d}{L} & 0 & -\frac{1-d}{L} \\ 0 & \frac{1-d}{C_2} & 0 \end{bmatrix} x(t) + \begin{bmatrix} -\frac{I_1}{C_1} \\ \frac{V_{pv}}{L} \\ -\frac{I_2}{C_2} \end{bmatrix} \quad (7)$$

where  $d_1 = d_2 = d \in \{0,1\}$ .


### 3. Proposed Voltage Balance Control

As aforementioned, the voltage balancing is required for appropriate operation of the bipolar DC microgrid. Therefore, an efficient controller aiming to maintain the capacitor voltages  $V_1$  and  $V_2$  of the TLBC equal is developed in this section.

#### 3.1. Design of the Proposed Backstepping-Based Controller

The structural view of the proposed controller is illustrated in Figure 6. It is based on a backstepping technique that has been proven very promising even for highly nonlinear systems. This technique ensures global stability and strong robustness against all parameter uncertainties [21]. The backstepping approach is a recursive strategy in which we can systematically design both feedback control laws and related Lyapunov functions.





**Figure 6.** Scheme of the proposed voltage-balancing control.

According to the discussion about the operation and the mathematical modeling already given in Section 2, the obtained model of TLSC can be presented as below:

$$\begin{cases} \dot{x}_1 = (1-d) \frac{x_2}{C_1} - \frac{I_1}{C_1} \\ \dot{x}_2 = -(1-d) \frac{x_1}{L} - (1-d) \frac{x_3}{L} + \frac{V_{pv}}{L} \\ \dot{x}_3 = (1-d) \frac{x_2}{C_2} - \frac{I_2}{C_2} \end{cases} \quad (8)$$

where  $x = [V_1 \quad i_L \quad V_2]^T$ .

To simplify the backstepping controller design, Equation (8) is rearranged as follow:

Define the variables  $y_1$  and  $y_2$  as

$$\begin{cases} y_1 = x_1 - x_3 \\ y_2 = x_2 \end{cases} \quad (9)$$

Their derivatives are obtained as

$$\begin{cases} \dot{y}_1 = \dot{x}_1 - \dot{x}_3 \\ \dot{y}_2 = \dot{x}_2 \end{cases} \quad (10)$$

From (8), we can form a new dynamic model as

$$\begin{cases} \dot{y}_1 = (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) y_2 - \frac{I_1}{C_1} + \frac{I_2}{C_2} \\ \dot{y}_2 = -\frac{(1-d)}{L} y_1 + \frac{V_{pv}}{L} \end{cases} \quad (11)$$

The procedure of designing the control law is described through the following steps:

Step1:

The errors are defined as

$$\begin{cases} z_1 = y_1 \\ z_2 = y_2 - \alpha_1 \end{cases} \quad (12)$$

where  $\alpha_1$  is the stabilizing function.

The objective is to make  $z_1 \mapsto 0$ . Consider a Lyapunov function  $V_1 = \frac{1}{2}z_1^2$ . Its time derivative is  $\dot{V}_1 = z_1 \dot{z}_1$ .

From (11) and (12)

$$\begin{aligned} \dot{z}_1 = \dot{y}_1 &= (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) y_2 - \frac{I_1}{C_1} + \frac{I_2}{C_2} \\ &= (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) (z_2 + \alpha_1) - \frac{I_1}{C_1} + \frac{I_2}{C_2} \end{aligned} \quad (13)$$

Thus,

$$\dot{V}_1 = z_1 \begin{bmatrix} (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) z_2 + (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) \alpha_1 \\ -\frac{I_1}{C_1} + \frac{I_2}{C_2} \end{bmatrix} \quad (14)$$

$\dot{V}_1$  must be a negative definite to guarantee the global asymptotic stability. Therefore,  $z_1 \dot{z}_1 < 0$  is a condition that can be imposed by taking the stabilizing function as

$$\begin{cases} \alpha_1 = \frac{1}{(1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right)} \left[ -k_1 z_1 - \left( -\frac{I_1}{C_1} + \frac{I_2}{C_2} \right) \right] \\ k_1 > 0 \end{cases} \quad (15)$$

We obtain

$$\dot{V}_1 = -k_1 z_1^2 + (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) z_1 z_2 \quad (16)$$

and

$$\dot{z}_1 = -k_1 z_1 + (1-d) \left( \frac{1}{C_1} - \frac{1}{C_2} \right) z_2 \quad (17)$$

Obviously, if  $z_2 = 0$ , then  $\dot{V}_1 = -k_1 z_1^2$ , and  $z_1$  is guaranteed to converge to zero asymptotically.

Step2:

We derive the error  $z_2$  as

$$z_2 = y_2 - \alpha_1 \xrightarrow{d/dt} \dot{z}_2 = \dot{y}_2 - \dot{\alpha}_1$$

Based on (11), the time derivative of  $z_2$  is

$$\dot{z}_2 = -\frac{(1-d)}{L} y_1 + \frac{V_{pv}}{L} - \dot{\alpha}_1 \quad (18)$$

The time derivative of  $\alpha_1$  is obtained as

$$\dot{\alpha}_1 = \frac{1}{(1-d)\left(\frac{1}{C_1} - \frac{1}{C_2}\right)} \left(-k_1 \dot{z}_1 - \frac{\dot{I}_2}{C_2} + \frac{\dot{I}_1}{C_1}\right) + \frac{\dot{d}}{\left(\frac{1}{C_1} - \frac{1}{C_2}\right)(1-d)^2} \left(-k_1 z_1 - \frac{I_2}{C_2} + \frac{I_1}{C_1}\right) \quad (19)$$

The Lyapunov function is chosen as

$$V_2 = V_1 + \frac{1}{2} z_2^2 \quad (20)$$

The time derivative of the Lyapunov function is expressed as

$$\dot{V}_2 = \dot{V}_1 + z_2 \dot{z}_2 \quad (21)$$

$$\begin{aligned} \dot{V}_2 &= -k_1 z_1^2 + (1-d) \left(\frac{1}{C_1} - \frac{1}{C_2}\right) z_1 z_2 + z_2 \dot{z}_2 \\ &= -k_1 z_1^2 + (1-d) \left(\frac{1}{C_1} - \frac{1}{C_2}\right) z_1 z_2 + z_2 \left(-\frac{(1-d)}{L} z_1 + \frac{V_{pv}}{L} - \dot{\alpha}_1\right) \\ &= -k_1 z_1^2 + z_2 \left[ (1-d) \left(\frac{1}{C_1} - \frac{1}{C_2} - \frac{1}{L}\right) z_1 + \frac{V_{pv}}{L} - \dot{\alpha}_1 \right] \end{aligned} \quad (22)$$

The derivative is negative definite by choosing

$$-k_2 z_2 = (1-d) \left(\frac{1}{C_1} - \frac{1}{C_2} - \frac{1}{L}\right) z_1 + \frac{V_{pv}}{L} - \dot{\alpha}_1 \quad (23)$$

As a result, the Lyapunov function derivative satisfies

$$\dot{V}_2 = -k_1 z_1^2 - k_2 z_2^2 > 0 \quad (24)$$

where  $k_1 > 0$   $k_2 > 0$ .

From (18) and (23), the time derivative of the error is expressed as

$$\dot{z}_2 = -k_2 z_2 - (1-d) \left(\frac{1}{C_1} - \frac{1}{C_2}\right) z_1 \quad (25)$$

Solving Equation (23) and using (19), the control law is synthesized as

$$\begin{aligned}
& (1-d)^2 \left[ \left( \frac{1}{C_1} - \frac{1}{C_2} - \frac{1}{L} \right) y_1 + (k_1 + k_2) y_2 + \frac{V_{pv}}{L} \right] \\
& + (1-d) \left[ \frac{k_2}{\left( \frac{1}{C_1} - \frac{1}{C_2} \right)} \left[ k_1 y_1 + \frac{I_2}{C_2} - \frac{I_1}{C_1} \right] + \frac{\left( \frac{I_2}{C_2} - \frac{I_1}{C_1} \right)}{\left( \frac{1}{C_1} - \frac{1}{C_2} \right)} + \frac{\left( \frac{I_2}{C_2} - \frac{I_1}{C_1} \right)}{\left( \frac{1}{C_1} - \frac{1}{C_2} \right)} \right] \\
& - d(1-d)^2 \left[ \left( \frac{1}{C_1} - \frac{1}{C_2} - \frac{1}{L} \right) y_1 \right] + \frac{\dot{d}}{\left( \frac{1}{C_1} - \frac{1}{C_2} \right)} \left[ k_1 y_1 + \frac{I_2}{C_2} - \frac{I_1}{C_1} \right] = 0
\end{aligned} \tag{26}$$

### 3.2. Parameters Selection of the Proposed Backstepping-Based Controller

For an optimal backstepping controller design, the unknown parameters  $k_1$  and  $k_2$  in the resulted control law shall be appropriately determined. The trial-and-error method is commonly used in solving a parameter estimation issue for most nonlinear controllers. However, such a method does not give the best setting of the parameters, and it is not a good solution especially when the complexity of the system increases. To deal with this issue, one of the different optimization algorithms presented in the literature, such as a genetic algorithm, particle swarm optimization, random search methods, ant colony optimization and shuffled frog leaping algorithm, can be employed. In this study, the particle swarm optimization (PSO) algorithm has been adopted.

The PSO is an evolutionary algorithm introduced by Elberhat and Kennedy in 1995 [22]. It is inspired from swarm behavior such as fish schooling and bird flocking. The PSO algorithm has been widely used for effectively solving optimization problems. It is characterized by its high quality, easy implementation and efficient computational performance [20].

The PSO algorithm is first initialized with a population of random particles and then searches the best solution through continuous process updates. An arbitrary velocity is assigned to each particle for propagating in the search space toward the optimum. Each particle has a memory used to remember the best previous position reached by it, which is named the personal best position ( $P_{best}$ ). The particle with the best  $P_{best}$  in the total swarm is called the global best particle ( $g_{best}$ ). Consider swarm-enclosed  $n$ -particles moving in a  $d$ -dimensional search space; the  $i$ th particle of the population can be defined by the  $d$ -dimensional vector  $X_i = (x_{i1}, x_{i2}, \dots, x_{id})$  and its velocity can be represented by another  $d$ -dimensional vector as  $V_i = (v_{i1}, v_{i2}, \dots, v_{id})$ . The following two equations (Equations (27) and (28)) are used to define the update of the particle's position.

$$V_{id}^{k+1} = wV_{id}^k + c_1 r_1 \left[ x_{id}^{P_{best}}(t) - x_{id}^k(t) \right] + c_2 r_2 \left[ x_{id}^{g_{best}}(t) - x_{id}^k(t) \right] \tag{27}$$

$$x_{id}^{k+1}(t+1) = x_{id}^k(t) + V_{id}^{k+1}(t+1) \tag{28}$$

where  $w$  is inertia weight,  $k$  is the number of iterations,  $c_1$  and  $c_2$  are called acceleration factors and  $r_1$  and  $r_2$  are random numbers uniformly distributed in the range  $[0, 1]$ .

In this study, two parameters need to be optimally predicted:  $k_1$  and  $k_2$ . The position can be defined as:

$$e = \int (V_1 - V_2)^2 \cdot t_r dt \tag{29}$$

where  $t_r$  is the time variable. The flowchart in Figure 7 illustrates the implementation of the PSO for parameters estimation of the proposed backstepping controller. The values

assigned to the PSO algorithm parameters in this study are given in Table 1. The simulation is performed using Matlab/Simulink. More simulation details are provided in Table 2. For the PSO search processing in the simulation, after 50 times iterations, the convergence plot and the trend of the best global position is obtained as depicted in Figure 8. The best global position  $e$  decreases and gradually maintains its stability with the iterations number increasing. At the end of program, the obtained parameters values are  $k_1 = 1200$  and  $k_2 = 154$ .




Figure 7. The PSO algorithm for optimal estimation of the backstepping controller parameters.




Figure 8. Trend of the best global position.

**Table 1.** The parameters values of the PSO algorithm.

Parameter	Value
Search space dimension $d$	2
Maximum number of iterations $k_{max}$	50
Number of particles $n$	100
$c_1$	0.8
$c_2$	1.2
Inertia weight $w$	0.8

**Table 2.** Simulation specifications.

	Parameter	Value
PV array 100 kW (Sunpower SPR-305E-WHT-D)	No. of cells per module	96
	Parallel strings	66
	Series connected modules per string	5
	Short circuit current $I_{sc}$	5.96 A
	Open circuit voltage $V_{oc}$	64.2 V
	Maximum power $P_{mpp}$	305.2 W
	Voltage at maximum power point $V_{mpp}$	54.7 V
	Current at maximum power point $I_{mpp}$	5.58 A
	Parameter	Value
	Output DC voltage ( $2V_{dc}$ )	$2 \times 350$ V
Three-level boost converter	Switching frequency	30 kHz
	Capacitors $C_1$ & $C_2$	1000 $\mu$ F
	Inductor L	270 $\mu$ H


#### 4. Simulation Results

In this section, simulation results are provided to validate the proposed controller for voltage balancing of a bipolar DC microgrid. Simulations are executed using MATLAB™/Simulink. The parameters used in the simulation are listed in Table 2.

Two main scenarios verifying the performance of the designed voltage-balancing controller and highlighting its importance in solving the imbalance issue in the bipolar DC microgrid caused by the asymmetrical loading were examined.

Scenario1:


First, the studied system was simulated without and with the voltage-balancing controller. In this test, resistive loads with different values were connected to the TLSC output (upper (positive to neutral) and lower (negative to neutral) terminals of the bipolar DC bus) to yield the voltage imbalance. The resulting waveforms are plotted in Figure 9. Before using the voltage-balancing control, there was a mismatch of about 267 V between the capacitor voltages  $V_1$  and  $V_2$ . Once the voltage-balancing control loop was applied at 0.3 s,  $V_1$  and  $V_2$  became equal, and the voltage balancing was immediately achieved. The proposed controller forced the difference between  $V_1$  and  $V_2$  to be zero.



**Figure 9.** Voltages of the upper and lower terminals before and after applying the voltage-balancing control loop.

### Scenario2:

In this scenario, the robustness of the proposed voltage-balancing controller was tested under varying load currents  $I_1$  and  $I_2$  as shown in Figure 10a. The obtained waveforms of the inductor current ( $i_L$ ) and the voltages ( $V_1$ ,  $V_2$ ,  $2V_{dc}$ ) are depicted in Figure 10. As can be seen, the developed controller kept the voltages of both terminals ( $V_1$  and  $V_2$ ) equal (350 V) despite the different step changes of the load currents. Hence, the proposed voltage-balancing controller showed good performance in terms of reliability.



**Figure 10.** The proposed voltage-balancing controller under varying loads current: (a) Output currents; (b) Inductor current; (c) Capacitor voltages; and (d) Output voltage.

### 5. Conclusions

In this paper, an advanced voltage-balancing control has been developed for a bipolar DC microgrid supplying unbalanced loads through a PV-fed three-level boost DC/DC converter. This converter topology was chosen in this study due to its merits compared to the conventional boost converter commonly used in DC microgrids, including higher reliability and efficiency. Moreover, the proposed voltage-balancing control strategy is based on a nonlinear backstepping approach, which ensures the robustness and the global asymptotic stability of the system proven throughout Lyapunov stability criteria. To enhance the dynamic performance of the proposed controller, PSO has been used for optimal estimation of its design parameters. The theoretical analysis was validated through simulations under Matlab/Simulink. The simulation results demonstrated the good performance of the proposed controller in terms of robustness and the settling time that is extremely small. Accordingly, the voltages of the upper (positive to neutral) and lower (negative to neutral) terminals of the bipolar DC microgrid are perfectly balanced, and the reliability of this system is improved. In future works, the proposed voltage-balancing control should be investigated experimentally.

**Author Contributions:** Conceptualization, H.D., I.S. and N.E.; Data curation, H.D., I.S. and N.E.; Formal analysis, H.D., I.S. and N.E.; Funding acquisition, H.D.; Investigation, H.D. and I.S.; Methodology, H.D. and I.S.; Project administration, I.S. and N.E.; Resources, N.E.; Software, H.D.; Supervision, I.S. and N.E.; Validation, H.D., I.S. and N.E.; Visualization, H.D.; Writing—original draft, H.D.; Writing—review & editing, I.S. and N.E. All authors have read and agreed to the published version of the manuscript.

**Funding:** This research was funded by the PHC Toubkal project (20/103-N°43692PB) And The APC was funded by Reims University.

**Acknowledgments:** This research work was financially supported by the PHC Toubkal project (20/103-N°43692PB).

**Conflicts of Interest:** The authors declare no conflict of interest.

### Abbreviations

DC	Direct Current
TLBC	Three-level DC/DC Boost converter
PSO	Particle swarm optimization
PWM	Pulse with modulation
CCM	Continuous conduction mode

### References

1. CORDIS European Commission. Cordis.europa.eu. 2019. Available online: <https://cordis.europa.eu/news/rcn/129412/en> (accessed on 12 December 2021).
2. Hirsch, A.; Parag, Y.; Guerrero, J. Microgrids: A review of technologies, key drivers, and outstanding issues. *Renew. Sustain. Energy Rev.* **2018**, *90*, 402–411. <https://doi.org/10.1016/j.rser.2018.03.040>.
3. Siemens. *The Genius of Microgrids in Higher Education*; Microgrid Knowledge Special Report; Siemens: Munich, Germany, 2020.
4. Wang, R.; Feng, W.; Xue, H.; Gerber, D.; Li, Y.; Hao, B.; Wang, Y. Simulation and power quality analysis of a Loose-Coupled bipolar DC microgrid in an office building. *Appl. Energy* **2021**, *303*, 117606. <https://doi.org/10.1016/j.apenergy.2021.117606>.
5. Justo, J.J.; Mwasilu, F.; Lee, J.; Jung, J.-W. AC-microgrids versus DC-microgrids with distributed energy resources: A review. *Renew. Sustain. Energy Rev.* **2013**, *24*, 387–405. <https://doi.org/10.1016/j.rser.2013.03.067>.
6. Ortiz, L.; González, J.W.; Gutierrez, L.B.; Llanes-Santiago, O. A review on control and fault-tolerant control systems of AC/DC microgrids. *Heliyon* **2020**, *6*, e04799. <https://doi.org/10.1016/j.heliyon.2020.e04799>.
7. Chen, D.; Xu, L. AC and DC Microgrid with Distributed Energy Resources. In *Technologies and Applications for Smart Charging of Electric and Plug-In Hybrid Vehicles*; Springer: Cham, Switzerland, 2016; pp. 39–64. [https://doi.org/10.1007/978-3-319-43651-7\\_2](https://doi.org/10.1007/978-3-319-43651-7_2).
8. Magdefrau, D.; Taufik, T.; Poshtan, M.; Muscarella, M. Analysis and Review of DC Microgrid Implementations. In Proceedings of the 2016 International Seminar on Application for Technology of Information and Communication, Semarang, Indonesia, 5–6 August 2016.
9. Dragičević, T.; Lu, X.; Vasquez, J.C.; Guerrero, J.M. DC microgrids—Part II: A review of power architectures, applications, and standardization issues. *IEEE Trans. Power Electron.* **2016**, *31*, 3528–3549.
10. Rodriguez-Diaz, E.; Chen, F.; Vasquez, J.C.; Guerrero, J.M.; Burgos, R.; Boroyevich, D. Voltage-level selection of future two-level lvdC distribution grids: A compromise between grid compatibility, safety, and efficiency. *IEEE Electr. Mag.* **2016**, *4*, 20–28.
11. Wang, F.; Lei, Z.; Xu, X.; Shu, X. Topology deduction and analysis of voltage balancers for DC microgrid. *IEEE J. Emerg. Sel. Top. Power Electron.* **2017**, *5*, 672–680. <https://doi.org/10.1109/JESTPE.2016.2638959>.
12. Chew, B.S.; Xu, Y.; Wu, Q. Voltage Balancing for Bipolar DC Distribution Grids: A Power Flow-based Binary Integer Multi-Objective Optimization Approach. *IEEE Trans. Power Syst.* **2018**, *34*, 28–39. <https://doi.org/10.1109/tpwrs.2018.2866817>.
13. Jadidi, S.; Badihi, H.; Zhang, Y. Passive Fault-Tolerant Model Predictive Control of AC/DC PWM Converter in a Hybrid Microgrid. *IFAC-PapersOnLine* **2020**, *53*, 12097–12102. <https://doi.org/10.1016/j.ifacol.2020.12.765>.
14. Tarasantisuk, C.; Chunkag, V.; Thounthong, P. Control of Parallel-connected AC to DC Converter with Droop Technique for DC Microgrid Application. *Energy Procedia* **2013**, *34*, 351–361. <https://doi.org/10.1016/j.egypro.2013.06.763>.
15. Nassar, W.M.; Anaya-Lara, O.; Ahmed, K.H. A new adaptive instantaneous average current sharing technique for circulating current minimization among parallel converters in a LV DC-microgrid. *Int. J. Electr. Power Energy Syst.* **2022**, *136*, 107562. <https://doi.org/10.1016/j.ijepes.2021.107562>.
16. Wu, B.; Gao, Z.; Zhou, X.; Ma, Y.; Wang, C. Research and Simulation of DC Microgrid Three-Phase AC-DC Converter Control Strategy Based on Double Loop. *IEEE Access* **2020**, *8*, 186448–186461. <https://doi.org/10.1109/ACCESS.2020.3030266>.
17. Teodorescu, R.; Blaabjerg, F.; Liserre, M.; Loh, P.C. Proportional-resonant controllers and filters for grid-connected. *IEE Proc. — Electr. Power Appl.* **2006**, *153*, 750–762. <https://doi.org/10.1049/ip-epa:20060008>.
18. Kumar, J.; Agarwal, A.; Agarwal, V. A review on overall control of DC microgrids. *J. Energy Storage* **2019**, *21*, 113–138.



19. Chen, H.-C.; Liao, J.-Y. Design and Implementation of Sensorless Capacitor Voltage Balancing Control for Three-Level Boosting PFC. *IEEE Trans. Power Electron.* **2014**, *29*, 3808–3817.
20. Sahab, M.G.; Toropov, V.V.; Gandomi, A.H. 2—A Review on Traditional and Modern Structural Optimization: Problems and Techniques. In *Metaheuristic Applications in Structures and Infrastructures*; Newnes: Oxford, UK; Boston, MA, USA, 2013; pp. 25–47.
21. Vaidyanathan, S.; Azar, A.T. *Backstepping Control of Nonlinear Dynamical Systems*; Advances in Nonlinear Dynamics and Chaos (ANDC); Elsevier Science: Amsterdam, The Netherlands, 2021; pp. 1–32. <https://doi.org/10.1016/C2018-0-02049-6>.
22. Mullane, A.; Lightbody, G.; Yacamini, R. Adaptive control of variable speed wind turbines. *Rev. Energ. Ren. Power Eng.* **2001**, 101–110. Available online: [https://www.cder.dz/vlib/revue/nspeciauxpdf/upec\\_13.pdf](https://www.cder.dz/vlib/revue/nspeciauxpdf/upec_13.pdf) (accessed on 27 April 2022).